

ID#	Type	Class	Protective Earth Resistance	Insulation Resistance	Leakage Current	Cord	Result	Notes
0001	Lighting	Class I	0.04Ω	> 19.99MΩ	<0.10mA		PASS	
0002	Lighting	Class I	0.05Ω	> 19.99MΩ	<0.10mA		PASS	
0003	Lighting	Class I	0.07Ω	> 19.99MΩ	<0.10mA		PASS	
0004	Lighting	Class I	0.04Ω	> 19.99MΩ	<0.10mA		PASS	
0005	Lighting	Class I	0.03Ω	> 19.99MΩ	0.20mA		PASS	
0006	Lighting	Class I	0.02Ω	> 19.99MΩ	0.17mA		PASS	
0007	Amplifier	Class I	0.05Ω	> 19.99MΩ	<0.10mA		PASS	
0008	Mixers	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	
0009	Mixers	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	
0010	Mixers	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	
0011	Mixers	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	
0012	Laptop	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0013	Laptop	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0014	Mixers	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0015	Lighting	Class II	No Continuity	> 19.99MΩ	<0.10mA		PASS	
0016	Lighting	Class II	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0017	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0018	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0019	Lighting	Class I	0.17Ω	> 19.99MΩ	0.17mA		PASS	3A Fuse
0020	Lighting	Class I	0.12Ω	> 19.99MΩ	0.17mA		PASS	3A Fuse
0021	Microphones	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	
0022	Lighting	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0023	Speakers	Class I	0.04Ω	> 19.99MΩ	1.03mA		PASS	IT Equipment < 3.0mA
0024	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	3A Fuse
0025	Speakers	Class I	0.06Ω	> 19.99MΩ	1.03mA		PASS	IT Equipment < 3.0mA
0026	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	3A Fuse
0027	Speakers	Class I	0.06Ω	> 19.99MΩ	0.64mA		PASS	IT Equipment < 3.0mA
0028	Speakers	Class I	0.09Ω	> 19.99MΩ	<0.10mA		PASS	IT Equipment < 3.0mA
0029	Speakers	Class I	0.05Ω	> 19.99MΩ	<0.10mA		PASS	IT Equipment < 3.0mA
0030	Cables	Cable	0.07Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0031	Cables	Cable	0.14Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0032	Effects	Class I	0.05Ω	> 19.99MΩ	<0.10mA		PASS	
0033	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0034	Lighting	Class I	0.03Ω	> 19.99MΩ	<0.10mA		PASS	
0035	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	3A Fuse
0036	Other	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	13A Fuse
0037	Other	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0038	Speakers	Class I	0.06Ω	> 19.99MΩ	0.87mA		PASS	IT Equipment < 3.0mA
0039	Speakers	Class I	0.07Ω	> 19.99MΩ	0.93mA		PASS	IT Equipment < 3.0mA
0040	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	
0041	Cables	Cable	0.02Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0042	Cables	Cable	0.01Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0043	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	
0044	Cables	Cable	0.13Ω	0.31MΩ		GOOD	PASS	Surge Protected 13A
0045	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0046	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0047								
0048	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	IEC TO IEC – BS1363A PLUG
0049	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	IEC TO IEC – BS1363A PLUG
0050	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0051	Cables	Cable						
0052	Cables	Cable	0.09Ω	> 19.99MΩ		OPEN	FAIL	Open Circuit on L/N
0053	Cables	Cable	0.09Ω	> 19.99MΩ		GOOD	PASS	10A Fuse
0054	Cables	Cable	0.07Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0055	Cables	Cable	0.01Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0056	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0057	Cables	Cable	0.1Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0058	Cables	Cable	0.1Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0059	Cables	Cable	0.09Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0060	Cables	Cable	0.1Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0061	Cables	Cable	0.09Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0062	Cables	Cable	0.09Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0063	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse

0064	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0065	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0066	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0067	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0068	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0069	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0070	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0071	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0072	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0073	Cables	Cable	0.06Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0074	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0075	Lighting	Class I	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0076	Lighting	Class I	0.03Ω	> 19.99MΩ	0.19mA		PASS	
0077	Effects	Class I	0.03Ω	> 19.99MΩ	<0.10mA		PASS	
0078	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0079	Lighting	Class I	0.09Ω	> 19.99MΩ	<0.10mA		PASS	
0080	Lighting	Class I	0.05Ω	> 19.99MΩ	<0.10mA		PASS	
0081	CD Player	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0082	CD Player	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0083	Other	Class II	No Continuity	> 19.99MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0084	Mixers	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	18C AC PSU
0085	Lighting	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	12V 2A PSU
0086	Lighting	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	12V 2A PSU
0087	Cables	Cable	0.01Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0088	Cables	Cable	0.02Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0089	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0090								
0091	Cables	Cable	0.07Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0092	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0093	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	IEC TO IEC
0094	Cables	Cable	0.02Ω	> 19.99MΩ		GOOD	PASS	IEC TO IEC
0095	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	IEC TO IEC
0096	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	IEC TO IEC
0097	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	10A Fuse
0098	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0099	Cables	Cable	0.02Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0100	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	3A Fuse
0101								
0102	Cables	Cable	0.20Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0103	Cables	Cable	0.20Ω	> 19.99MΩ		GOOD	PASS	10A Fuse
0104	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0105	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	10A Fuse
0106	Cables	Cable	0.07Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0107	Cables	Cable	0.07Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0108	Cables	Cable	0.10Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0109	Cables	Cable	0.19Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0110	Amplifier	Class I	0.04Ω	> 19.99MΩ	0.11mA		PASS	13A Fuse
0111	Amplifier	Class I	0.08Ω	> 19.99MΩ	0.25mA		PASS	13A Fuse
0112	Microphones	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	10.5V 0.25A PSU
0113								
0114								
0115								
0116	Cables	Cable	0.02Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0117	Lighting	Class I	0.14Ω	19.99MΩ	< 0.10mA			3A Fuse
0118	Lighting	Class I	0.06Ω	19.99MΩ	< 0.10mA			3A Fuse
0119	Other	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0120	Lighting	Class I						
0121	Lighting	Class I						
0122	Lighting	Class I	0.12Ω	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0123	Lighting	Class I	0.11	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0124	Cables	Cable	0.26Ω	> 19.99MΩ		GOOD	PASS	0.30mA Limit 10a Fuse
0125	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0126	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0127	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	13A Fuse

0128	Cables	Cable	0.03Ω	0.30MΩ		GOOD	PASS	Riso Fail Tested at 500v 13A fuse
0129	Cables	Cable	0.05Ω	0.31MΩ		GOOD	PASS	Riso Fail Tested at 500v 13A fuse
0130	Cables	Cable	0.04Ω	0.30MΩ		GOOD	PASS	Riso Fail Tested at 500v 13A fuse
0131	Cables	Cable	0.04Ω	0.30MΩ		GOOD	PASS	Riso Fail Tested at 500v 13A fuse
0132	Cables	Cable	0.09Ω	> 19.99MΩ		GOOD	PASS	10A Fuse
0133	Cables	Cable	0.21Ω	> 19.99MΩ		GOOD	PASS	0.25Ω Rpe Limit for 1.5mm CSA 13A
0134	Cables	Cable	0.18Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0135	Lighting	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	
0136	Lighting	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0137	Lighting	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	3A Fuse
0138	Speakers	Class I	0.03Ω	> 19.99MΩ	0.98mA		PASS	IT Equipment < 3.5mA
0139	Cables	Cable	0.01Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0140	Speakers	Class I	0.04Ω	> 19.99MΩ	1.06mA		PASS	IT Equipment < 3.5mA
0141	Cables	Cable	0.02Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0142	Speakers	Class I	0.03Ω	> 19.99MΩ	0.93mA		PASS	IT Equipment < 3.5mA
0143	Cables	Cable	0.02Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0144	Cables	Cable	0.39Ω	> 19.99MΩ		GOOD	PASS	(0.49mA Limit) 13a Fuse
0145	Cables	Cable	0.02Ω	> 19.99MΩ		GOOD	PASS	3A Fuse
0146	Other	Other	0.01Ω	> 19.99MΩ		GOOD	PASS	RCD Protector
0147	Cables	Cable	0.05Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0148	Cables	Cable	0.06Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0149	Cables	Cable	0.06Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0150	Cables	Cable	0.04Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0151	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	13A Fuse
0152	Other	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	12v 1A PSU
0153	Lights	Class I	0.02Ω	> 19.99MΩ	<0.10mA		PASS	
0154	Lighting	Class I	0.05Ω	> 19.99MΩ	<0.10mA		PASS	
0155	Cables	Cable	0.03Ω	> 19.99MΩ		GOOD	PASS	5A Fuse
0156	Other	Other	0.01Ω	> 19.99MΩ		GOOD	PASS	13A Fused
0157	Microphones	ClassII	Double Insulated	> 19.99MΩ	<0.10mA		PASS	12V 0.4A PSU
0158	Laptop	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	Plastic Case 18.5V 3.5a PSU
0159	Lights	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	31V PSU
0160	Lights	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	31V PSU
0161	Heater	Class II	Double Insulated	> 19.99MΩ	<0.10mA		PASS	13A Fuse
0162	Cables	Cable	0.11Ω	> 19.99MΩ		GOOD	PASS	13A Fuse

