

ID#	Type	Class	Protective Earth Resistance	Insulation Resistance	Leakage Current	Cord	Result	Notes
0001	Lighting	Class I	0.04Ω	>19.99 MΩ	<0.10mA		PASS	
0002	Lighting	Class I	0.06Ω	>19.99 MΩ	<0.10mA		PASS	
0003	Lighting	Class I	0.07Ω	>19.99 MΩ	<0.10mA		PASS	
0004	Lighting	Class I	0.05Ω	>19.99 MΩ	<0.10mA		PASS	
0005	Lighting	Class I	0.04Ω	>19.99 MΩ	0.17mA		PASS	
0006	Lighting	Class I	0.04Ω	>19.99 MΩ	0.16mA		PASS	
0007	Amplifier	Class I	0.06Ω	>19.99 MΩ	<0.10mA		PASS	
0008	Mixers	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	
0009	Mixers	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	
0010	Mixers	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	
0011	Mixers	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	
0012	Laptop	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0013	Laptop	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0014	Mixers	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0015	Lighting	Class II	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0016	Lighting	Class II	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0017	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0018	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0019	Lighting	Class I	0.14Ω	>19.99 MΩ	0.16mA		PASS	3A Fuse
0020	Lighting	Class I	0.13Ω	>19.99 MΩ	0.15mA		PASS	3A Fuse
0021	Microphones	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	
0022	Lighting	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0023	Speakers	Class I	0.04Ω	>19.99 MΩ	0.92mA		PASS	IT Equipment < 3.0mA
0024	Cables	Cable	0.08Ω	>19.99 MΩ		Y	PASS	13A Fuse
0025	Speakers	Class I	0.05Ω	>19.99 MΩ	0.94mA		PASS	IT Equipment < 3.0mA
0026	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	13A Fuse
0027	Speakers	Class I	0.05Ω	>19.99 MΩ	0.79mA		PASS	IT Equipment < 3.0mA
0028	Speakers	Class I	0.11Ω	>19.99 MΩ	<0.10mA		PASS	IT Equipment < 3.0mA
0029	Speakers	Class I	0.1Ω	>19.99 MΩ	<0.10mA		PASS	IT Equipment < 3.0mA
0030	Cables	Cable	0.07Ω	>19.99 MΩ		Y	PASS	5A Fuse
0031	Cables	Cable	0.18Ω	>19.99 MΩ		Y	PASS	5A Fuse
0032	Effects	Class I	0.07Ω	>19.99 MΩ	<0.10mA		PASS	
0033	Cables	Cable	0.04Ω	>19.99 MΩ			PASS	5A Fuse
0034	Lighting	Class I	0.11Ω	>19.99 MΩ	<0.10mA		PASS	
0035	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	3A Fuse
0036	Other	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	13A Fuse
0037	Other	Class II	Double Insulated	>19.99 MΩ	<0.10mA			3A Fuse
0038	Speakers	Class I	0.05Ω	>19.99 MΩ	0.86mA		PASS	IT Equipment < 3.0mA
0039	Speakers	Class I	0.11Ω	>19.99 MΩ	0.80mA		PASS	IT Equipment < 3.0mA
0040	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	13A Fuse
0041	Cables	Cable	0.02Ω	>19.99 MΩ		Y	PASS	13A Fuse
0042	Cables	Cable	0.02Ω	>19.99 MΩ		Y	PASS	13A Fuse
0043	Cables	Cable	0.06Ω	>19.99 MΩ		Y	PASS	13A Fuse
0044	Cables	Cable	0.15Ω	>19.99 MΩ	0.31mA	Y	PASS	Riso Fail Tested at 500v 13A fuse
0045	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	13A Fuse
0046	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	13A Fuse
0047	Cables	Cable	0.07Ω	>19.99 MΩ		Y	PASS	3A Fuse
0048	Mixers	Mixer	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0049	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	IEC TO IEC – BS1363A PLUG
0050								
0051	Cables	Cable	0.07Ω	>19.99 MΩ		Y	PASS	13A Fuse
0052	Cables	Cable	0.03Ω	>19.99 MΩ		Y	PASS	IEC TO IEC
0053	Cables	Cable	0.11Ω	>19.99 MΩ		Y	PASS	10A Fuse
0054	Cables	Cable	0.07Ω	>19.99 MΩ		Y	PASS	5A Fuse
0055	Cables	Cable	0.02Ω	>19.99 MΩ		Y	PASS	13A Fuse
0056	Cables	Cable	0.06Ω	>19.99 MΩ		Y	PASS	5A Fuse
0057	Cables	Cable	0.10Ω	>19.99 MΩ		Y	PASS	13A Fuse
0058	Cables	Cable	0.09Ω	>19.99 MΩ		Y	PASS	13A Fuse
0059	Cables	Cable	0.10Ω	>19.99 MΩ		Y	PASS	13A Fuse
0060	Cables	Cable	0.12Ω	>19.99 MΩ		Y	PASS	13A Fuse
0061	Cables	Cable	0.10Ω	>19.99 MΩ		Y	PASS	13A Fuse
0062	Cables	Cable	0.09Ω	>19.99 MΩ		Y	PASS	13A Fuse
0063	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse

0064	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0065	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0066	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0067	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0068	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0069	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0070	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0071	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0072	Lighting	Class I	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body, No Exposed Metal. 3A Fuse
0073	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	13A Fuse
0074								
0075								
0076	Lighting	Class I	0.08Ω	>19.99 MΩ	0.19mA		PASS	
0077	Effects	Class I	0.07Ω	>19.99 MΩ	<0.10mA		PASS	
0078	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	5A Fuse
0079	Lighting	Class I	0.12Ω	>19.99 MΩ	<0.10mA		PASS	
0080	Lighting	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0081	CD Player	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0082	CD Player	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0083	Other	Class II	No Continuity	>19.99 MΩ	<0.10mA		PASS	Plastic Body 3A Fuse
0084	Mixers	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	18C AC PSU
0085	Lighting	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	12V 2A PSU
0086	Lighting	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	12V 2A PSU
0087	Cables	Cable	0.01Ω	>19.99 MΩ		Y	PASS	13A Fuse
0088	Cables	Cable	0.02Ω	>19.99 MΩ		Y	PASS	13A Fuse
0089	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	13A Fuse
0090	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	13A Fuse
0091	Cables	Cable	0.07Ω	>19.99 MΩ		Y	PASS	13A Fuse
0092	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	13A Fuse
0093	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	IEC TO IEC
0094	Cables	Cable	0.03Ω	>19.99 MΩ		Y	PASS	IEC TO IEC
0095	Cables	Cable	0.03Ω	>19.99 MΩ		Y	PASS	IEC TO IEC
0096	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	IEC TO IEC
0097	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	10A Fuse
0098	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	5A Fuse
0099	Cables	Cable	0.03Ω	>19.99 MΩ		Y	PASS	13A Fuse
0100	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	5A Fuse
0101	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	
0102	Cables	Cable	0.19Ω	>19.99 MΩ		Y	PASS	13A Fuse
0103	Cables	Cable	0.2Ω	>19.99 MΩ		Y	PASS	10A Fuse
0104	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	13A Fuse
0105								
0106	Cables	Cable	0.06Ω	>19.99 MΩ		Y	PASS	5A Fuse
0107	Cables	Cable	0.08Ω	>19.99 MΩ		Y	PASS	5A Fuse
0108	Cables	Cable	0.13Ω	>19.99 MΩ		Y	PASS	5A Fuse
0109	Cables	Cable	0.2Ω	>19.99 MΩ		Y	PASS	13A Fuse
0110	Amplifier	Class I	0.13Ω	>19.99 MΩ	0.24mA		PASS	13A Fuse
0111	Cables		0.02Ω	>19.99 MΩ		Y	PASS	13A Fuse
0112	Microphones	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	10.5V 0.25A PSU
0113	Cables		0.02Ω	>19.99 MΩ		Y	PASS	13A Fuse
0114	Speakers	Class 1	0.08Ω	>19.99 MΩ	0.88mA		PASS	IT Equipment < 3.0mA
0115	Speakers	Class 1	0.12Ω	>19.99 MΩ	0.86mA		PASS	IT Equipment < 3.0mA
0116	Cables	Cable	0.02Ω	>19.99 MΩ		Y	PASS	13A Fuse
0117	Lighting	Class I	0.13Ω	>19.99 MΩ	<0.10mA		PASS	5A Fuse
0118								
0119	Other	ClassII	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0120								
0121								
0122	Lighting	Class I	0.08Ω	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0123	Lighting	Class I	0.10Ω	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0124	Cables	Cable	0.20Ω	>19.99 MΩ	<0.10mA	Y	PASS	0.30mA Limit 10a Fuse
0125	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	13A Fuse
0126	Cables	Cable	0.05Ω	>19.99 MΩ		Y	FAIL	Inner Insulation Exposed.
0127	Cables	Cable	0.06Ω	>19.99 MΩ		Y	PASS	13A Fuse

0128	Cables	Cable	0.05Ω	>19.99 MΩ	0.30mA	Y	PASS	Riso Fail Tested at 500v 13A fuse
0129	Cables	Cable	0.04Ω	>19.99 MΩ	0.31mA	Y	PASS	Riso Fail Tested at 500v 13A fuse
0130	Cables	Cable	0.04Ω	>19.99 MΩ	0.30mA	Y	PASS	Riso Fail Tested at 500v 13A fuse
0131	Cables	Cable	0.05Ω	>19.99 MΩ	0.31mA	Y	PASS	Riso Fail Tested at 500v 13A fuse
0132								
0133	Cables	Cable	0.24Ω	>19.99 MΩ		Y	PASS	0.25Ω Rpe Limit for 1.5mm CSA 13A
0134	Cables	Cable	0.17Ω	>19.99 MΩ		Y	PASS	13A Fuse
0135								
0136	Lighting	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	3A Fuse
0137	Lighting	Class II	Double Insulated	>19.99 MΩ	<0.10mA			3A Fuse
0138	Speakers	Class I	0.07Ω	>19.99 MΩ	0.80mA		PASS	IT Equipment < 3..5mA
0139	Cables	Cable	0.02Ω	>19.99 MΩ		Y	PASS	13A Fuse
0140	Speakers	Class I	0.07Ω	>19.99 MΩ	0.89mA		PASS	IT Equipment < 3..5mA
0141	Cables	Cable	0.05Ω	>19.99 MΩ		Y	PASS	13A Fuse
0142	Speakers	Class I	0.03Ω	>19.99 MΩ	0.81mA		PASS	IT Equipment < 3..5mA
0143	Cables	Cable	0.06Ω	>19.99 MΩ		Y	PASS	13A Fuse
0144	Cables	Cable	0.39Ω	>19.99 MΩ		Y	PASS	(0.49mA Limit) 13a Fuse
0145	Cables	Cable	0.02Ω	>19.99 MΩ		Y	PASS	3A Fuse
0146	Other	Other	0.01Ω	>19.99 MΩ		Y	PASS	RCD Protector
0147	Cables	Cable	0.07Ω	>19.99 MΩ		Y	PASS	13A Fuse
0148	Cables	Cable	0.08Ω	>19.99 MΩ		Y	PASS	13A Fuse
0149	Cables	Cable	0.07Ω	>19.99 MΩ		Y	PASS	13A Fuse
0150	Cables	Cable	0.06Ω	>19.99 MΩ		Y	PASS	13A Fuse
0151	Cables	Cable	0.03Ω	>19.99 MΩ		Y	PASS	13A Fuse
0152	Other	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	12v 1A PSU
0153								
0154	Lighting	Class I	0.05Ω	>19.99 MΩ	0.11mA		PASS	
0155	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	5A Fuse
0156	Other	Other	0.01Ω	>19.99 MΩ		Y	PASS	13A Fused
0157	Microphones	ClassII	Double Insulated	>19.99 MΩ	<0.10mA		PASS	12V 0.4A PSU 3A Fuse
0158	Laptop	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	Plastic Case 18.5V 3.5a PSU
0159				>19.99 MΩ				
0160	Lights	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	31V PSU
0161	Heater	Class II	Double Insulated	>19.99 MΩ	<0.10mA		PASS	13A Fuse
0162	Cables	Cable	0.11Ω	>19.99 MΩ		Y	PASS	13A Fuse
0163	Light	Class I	0.04Ω	>19.99 MΩ	<0.10mA		PASS	
0164	Light	Class I	0.04Ω	>19.99 MΩ	<0.10mA		PASS	
0165	Light	Class I	0.03Ω	>19.99 MΩ	<0.10mA		PASS	
0166	Light	Class I	0.03Ω	>19.99 MΩ	<0.10mA		PASS	
0167	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	5A Fuse
0168	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	5A Fuse
0169	Cables	Cable	0.01Ω	>19.99 MΩ		Y	PASS	3A Fuse
0170	Cables	Cable	0.01Ω	>19.99 MΩ		Y	PASS	3A Fuse
0171	Cables	Cable	0.08Ω	>19.99 MΩ		Y	PASS	13A Fuse
0172	Cables	Cable	0.08Ω	>19.99 MΩ		Y	PASS	13A Fuse
0173	Cables	Cable	0.08Ω	>19.99 MΩ		Y	PASS	13A Fuse
0174	Cables	Cable	0.08Ω	>19.99 MΩ		Y	PASS	13A Fuse
0175	Cables	Cable	0.09Ω	>19.99 MΩ		Y	PASS	5A Fuse
0176	Cables	Cable	0.12Ω	>19.99 MΩ		Y	PASS	5A Fuse
0177	Cables	Cable	0.04Ω	>19.99 MΩ		Y	PASS	5A Fuse
0178	Cables	Cable	0.06Ω	>19.99 MΩ		Y	PASS	5A Fuse





