ID#	Type	Class	Protective Earth Resistance	Insulation Resistance	Leakage Current	Cord	Result
0001	Lighting		2014	Class I	0.08Ω	>19.99MΩ	<0.10mA
0002	Lighting		2014	Class I	0.07Ω	>19.99MΩ	<0.10mA
0003	Lighting	17020004	08/05/18	Class I	0.11Ω	>19.99MΩ	<0.10mA
0004	Lighting	17020005	08/05/18	Class I	0.12Ω	>19.99MΩ	<0.10mA
0005	Lighting		31/12/17	Class I	0.06Ω	>19.99MΩ	0.16mA
0006	Lighting		31/12/17	Class I	0.05Ω	>19.99MΩ	0.15mA
0007	Amplifier	10/001408-	2013	Class I	0.06Ω	>19.99MΩ	<0.10mA
0008	Mixers	T160510179870		Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0009	Cable			Cable	0.07Ω	>19.99MΩ	
0010	Mixers	006-09160	10/09/17	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0011	Mixers	T15021016	04/12/16	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0012	Laptop	K00620809	2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0013	Laptop	20451253F	2019	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0014	Cable			Cable	0.12Ω	>19.99MΩ	
0015	Lighting		26/04/17	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0016	Lighting		26/04/17	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0017							
0018							
0019	Lighting	909/1734	23/11/13	Class I	0.16Ω	>19.99MΩ	<0.10mA
0020	Lighting	908/0239	23/11/13	Class I	0.14Ω	>19.99MΩ	<0.10mA
0021	Microphones	T17125271	08/04/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0022	Lighting		2024	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0023	Speakers	T17091129	06/01/18	Class I	0.03Ω	>19.99MΩ	0.89mA
0024	Cables		27/07/19	Cable	0.05Ω	>19.99MΩ	
0025	Speakers	T17091129	06/01/18	Class I	0.03Ω	>19.99MΩ	0.89mA
0026	Cables		06/01/18	Cable	0.03Ω	>19.99MΩ	
0027	Speakers	T18031146	19/07/18	Class I	0.03Ω	>19.99MΩ	0.79mA
0028	Speakers		14/01/17	Class I	0.1Ω	>19.99MΩ	<0.10mA
0029	Speakers		14/01/17	Class I	0.09Ω	>19.99MΩ	<0.10mA
0030	Cables			Cable	0.07Ω	>19.99MΩ	
0031	Cables			Cable	0.11Ω	>19.99MΩ	
0032	Effects	159-04170	02/01/18	Class I	0.06Ω	>19.99MΩ	<0.10mA
0033	Cables		02/01/18	Cable	0.05Ω	>19.99MΩ	
0034	Lighting	2.0E+010	25/07/17	Class I	0.03Ω	>19.99MΩ	>10mA
0035							
0036	Other		2017	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0037	Other	435686/1	2017	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0038	Speakers	T17011148	06/01/18	Class I	0.03Ω	>19.99MΩ	0.86mA
0039	Speakers	T17081148	06/01/18	Class I	0.014Ω	>19.99MΩ	0.79mA
0040	Cables			Cable	0.12Ω	>19.99MΩ	
0041							
0042	Cables			Cable	0.05Ω	>19.99MΩ	0.31mA
0043	Cables			Cable	0.04Ω	>19.99MΩ	
0044	Cables		20/04/17	Cable	0.14Ω	>19.99MΩ	0.31mA
0045							
0046	Cables			Cable	0.07Ω	>19.99MΩ	
0047							
0048	Mixers	KMP00966I	02/02/21	Mixer	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0049	Cables		09/04/18	Cable	0.04Ω	>19.99MΩ	
0050	Cable			Cable	0.05Ω	>19.99MΩ	0.30mA
0051	Cables			Cable	0.07Ω	>19.99MΩ	
0052							
0053	Cables			Cable	0.03Ω	>19.99MΩ	
0054	Cables			Cable	0.07Ω	>19.99MΩ	
0055	Cables			Cable	0.03Ω	>19.99MΩ	
0056	Cables			Cable	0.06Ω	>19.99MΩ	
0057	Cables		17/06/18	Cable	0.13Ω	>19.99MΩ	
0058	Cables		17/06/18	Cable	0.10Ω	>19.99MΩ	
0059	Cables		17/06/18	Cable	0.17Ω	>19.99MΩ	
0060	Cables		17/06/18	Cable	0.13Ω	>19.99MΩ	
0061	Cables		17/06/18	Cable	0.12Ω	>19.99MΩ	
0062	Cables		17/06/18	Cable	0.08Ω	>19.99MΩ	
0063	Cables			Cable	0.02Ω	>19.99MΩ	

0064	Cables			Cable	0.03Ω	>19.99MΩ	
0065	Lighting		15/06/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0066	Lighting		15/06/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0067	Lighting		15/06/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0068							
0069	Lighting		15/06/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0070	Lighting		15/06/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0071	Lighting		15/06/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0072							
0073	Cable			Cable	0.05Ω	>19.99MΩ	0.31mA
0074	Lighting		2024	Class 1	0.04Ω	>19.99MΩ	<0.10mA
0075	Lighting		2024	Class 1	0.05Ω	>19.99MΩ	<0.10mA
0076	Lighting		31/12/17	Class I	0.04Ω	>19.99MΩ	0.18mA
0077	Effects		07/10/17	Class I	0.03Ω	>19.99MΩ	<0.10mA
0078	Cables		07/10/17	Cable	0.10Ω	>19.99MΩ	
0079							
0080	Lighting		2024	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0081	CD Player	'17000517(	02/05/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0082	CD Player	'18000872-	03/08/18	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0083							
0084	Mixers	T14091017	01/07/17	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0085							
0086							
0087	Cables			Cable	0.02Ω	>19.99MΩ	
0088							
0089							
0090	Cables			Cable	0.07Ω	>19.99MΩ	
0091	Cables			Cable	0.08Ω	>19.99MΩ	
0092	Cables			Cable	0.05Ω	>19.99MΩ	
0093	Cables		09/04/18	Cable	0.05Ω	>19.99MΩ	
0094	Cables		09/04/18	Cable	0.04Ω	>19.99MΩ	
0095							
0096	Cables		09/04/18	Cable	0.05Ω	>19.99MΩ	
0097	Cables			Cable	0.04Ω	>19.99MΩ	
0098	Cables			Cable	0.06Ω	>19.99MΩ	
0099	Cables			Cable	0.03Ω	>19.99MΩ	
0100							
0101	Cables			Cable	0.06Ω	>19.99MΩ	
0102							
0103	Cables		23/05/17	Cable	0.20Ω	>19.99MΩ	
0104	Cables			Cable	0.09Ω	>19.99MΩ	
0105							
0106							
0107	Cables			Cable	0.05Ω	>19.99MΩ	
0108	Cables			Cable	0.25Ω	>19.99MΩ	
0109	Cables			Cable	0.19Ω	>19.99MΩ	
0110	Amplifier	6100162	23/07/17	Class I	0.014Ω	>19.99MΩ	<0.10mA
0111							
0112	Microphones	171.801		Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0113							
0114	Speakers	T19111177	10/02/20	Class 1	0.03Ω	>19.99MΩ	0.84mA
0115	Speakers	T19111177	10/02/20	Class 1	0.03Ω	>19.99MΩ	0.84mA
0116							
0117	Lighting		2013	Class I	0.13Ω	>19.99MΩ	<0.10mA
0118	Monitor			Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0119	Other	140410		ClassII			
0120	Cables		06/01/18	Cable	0.05Ω	>19.99MΩ	
0121	Effects	BSB500		Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0122	Lighting		18/04/13	Class I	0.13Ω	>19.99MΩ	<0.10mA
0123	Lighting		18/04/13	Class I	0.09Ω	>19.99MΩ	<0.10mA
0124	Cables			Cable	needs repair	in shed	
0125	Cables		20/04/17	Cable	0.06Ω	>19.99MΩ	
0126							
0127							

0128	Cables		25/11/18	Cable	0.08Ω	>19.99MΩ	0.31Ma
0129	Cables		25/11/18	Cable	0.07Ω	>19.99MΩ	0.31mA
0130	Cables		25/11/18	Cable	0.06Ω	>19.99MΩ	0.30mA
0131							
0132	Cable			Cable	0.03Ω	>19.99MΩ	
0133	Cables			Cable	0.21Ω	>19.99MΩ	
0134	Cables			Cable	0.18Ω	>19.99MΩ	
0135							
0136							
0137	Cables			Cable	0.04Ω	>19.99MΩ	
0138	Speakers	T16061146	27/07/19	Class I	0.02Ω	>19.99MΩ	0.79mA
0139	Cables		27/07/19	Cable	0.03Ω	>19.99MΩ	0.89mA
0140	Speakers	T16091128	27/07/19	Class I	0.05Ω	>19.99MΩ	0.88mA
0141	Cables		27/07/19	Cable	0.02Ω	>19.99MΩ	
0142	Speakers	T16081128	27/07/19	Class I	0.03Ω	>19.99MΩ	0.81mA
0143	Cables		27/07/19	Cable	0.05Ω	>19.99MΩ	0.78mA
0144	Cables	CTH2513		Cable	0.40Ω	>19.99MΩ	
0145							
0146	Other	ES111		Other	0.01Ω	>19.99MΩ	
0147	Cables			Cable	0.06Ω	>19.99MΩ	
0148	Cables			Cable	0.08Ω	>19.99MΩ	
0149	Cables			Cable	0.07Ω	>19.99MΩ	
0150	Cables			Cable	0.06Ω	>19.99MΩ	
0151	Cables			Cable	0.07Ω	>19.99MΩ	
0152	Other	1.0E+018	08/11/19	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0153	Cable			Cable	0.08Ω	>19.99MΩ	
0154							
0155							
0156	Other			Other	0.01Ω	>19.99MΩ	
0157	Microphones	3.1E+008		Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0158							
0159	Cable			Cable	0.03Ω	>19.99MΩ	
0160							
0161							
0162							
0163	Light	437		Class I	0.03Ω	>19.99MΩ	<0.10mA
0164	Light	435		Class I	0.06Ω	>19.99MΩ	<0.10mA
0165	Light	436		Class I	0.05Ω	>19.99MΩ	<0.10mA
0166	Light	439		Class I	0.03Ω	>19.99MΩ	<0.10mA
0167							
0168	Cable		2024	Cable	0.04Ω	>19.99MΩ	
0169	Cables			Cable	0.07Ω	>19.99MΩ	
0170							
0171	Cables			Cable	0.09Ω	>19.99MΩ	
0172	Cables			Cable	0.09Ω	>19.99MΩ	
0173	Cables			Cable	0.11Ω	>19.99MΩ	
0174	Cables			Cable	0.09Ω	>19.99MΩ	
0175							
0176	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0177	Cables			Cable	0.05Ω	>19.99MΩ	
0178							
0179	Cables			Cable	0.02Ω	>19.99MΩ	
0180	Cables		2022	Cable	0.09Ω	>19.99MΩ	0.32mA
0181	Cables		2022	Cable	0.10Ω	>19.99MΩ	0.32mA
0182	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0183	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0184	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0185	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0186	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0187	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0188	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0189							
0190							
0191	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA

0192	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0193	Light		2022	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0194	Speakers	T16121134	2022	Class I	0.02Ω	>19.99MΩ	0.87mA
0195	Speakers	T16111134	2022	Class I	0.03Ω	>19.99MΩ	0.87mA
0196	Cable		2022	Cable	0.05Ω	>19.99MΩ	
0197	Cable		2022	Cable	0.08Ω	>19.99MΩ	
0198							
0199							
0200							
0201	Cable			Cable	0.05Ω	>19.99MΩ	0.31mA
0202	Cable			Cable	0.06Ω	>19.99MΩ	0.30mA
0203	Cable			Cable	0.05Ω	>19.99MΩ	0.32mA
0204	Cable			Cable	0.06Ω	>19.99MΩ	0.32mA
0205	Cable			Cable	0.05Ω	>19.99MΩ	0.31mA
0206	Cable			Cable	0.05Ω	>19.99MΩ	0.30mA
0207							
0208	Microphones	810527100	2021	Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0209	Cables						
0210	Light	UXS19576	2022	Class 1	0.06Ω	>19.99MΩ	0.12mA
0211	Light	UXS19577	2022	Class 1	0.07Ω	>19.99MΩ	0.14mA
0212	Cable		2022	Cable	0.04Ω	>19.99MΩ	
0213	Cable		2022	Cable	0.03Ω	>19.99MΩ	
0214							
0215	PSU			Class II	DOUBLE INSULATED	>19.99MΩ	<0.10mA
0216							
0217							
0218							
0219							
0220	Cable			Cable	0.68Ω	>19.99MΩ	
0221	Cable			Cable	0.68Ω	>19.99MΩ	
0222	Cable			Cable	0.70Ω	>19.99MΩ	
0223	Cable			Cable	0.10Ω	>19.99MΩ	
0224	Cable			Cable	0.06Ω	>19.99MΩ	

Notes		
	PASS	
	PASS	
	PASS	
	PASS	
	PASS	
	PASS	
	PASS	
GOOD	PASS	5A Fuse
	PASS	
	PASS	
	PASS	3A Fuse
	PASS	3A Fuse
GOOD	PASS	10A Fuse
	PASS	Plastic Body 3A Fuse
	PASS	Plastic Body 3A Fuse
	PASS	3A Fuse
	PASS	3A Fuse
		3A Fuse
		IT Equipment < 3.0mA
GOOD	PASS	5A Fuse
	PASS	IT Equipment < 3.0mA
GOOD	PASS	13A Fuse
	PASS	IT Equipment < 3.0mA
	PASS	IT Equipment < 3.0mA
	PASS	IT Equipment < 3.0mA
GOOD	PASS	5A Fuse
GOOD	PASS	5A Fuse
	PASS	
GOOD	PASS	5A Fuse
	PASS	
	PASS	13A Fuse
	PASS	3A Fuse
		IT Equipment < 3.0mA
		IT Equipment < 3.0mA
GOOD	PASS	13A Fuse
GOOD	PASS	
GOOD	PASS	13A Fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	13A Fuse
	PASS	3A Fuse
GOOD	PASS	IEC TO IEC – BS1363A PLUG
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	5A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	5A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse

GOOD	PASS	13A Fuse
	PASS	Plastic Body, No Exposed Metal. 3A Fuse
	PASS	Plastic Body, No Exposed Metal. 3A Fuse
	PASS	Plastic Body, No Exposed Metal. 3A Fuse
	PASS	Plastic Body, No Exposed Metal. 3A Fuse
	PASS	Plastic Body, No Exposed Metal. 3A Fuse
	PASS	Plastic Body, No Exposed Metal. 3A Fuse
GOOD	PASS	13A Fuse
	PASS	
	PASS	
	PASS	
	PASS	
GOOD	PASS	5A Fuse
	PASS	3A Fuse
	PASS	3A Fuse
	PASS	3A Fuse
	PASS	18v AC PSU
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	IEC TO IEC
GOOD	PASS	IEC TO IEC
GOOD	PASS	IEC TO IEC
GOOD	PASS	10A Fuse
GOOD	PASS	5A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	10A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	5A Fuse
GOOD	FAIL	5A Fuse
GOOD	PASS	13A Fuse
	PASS	13A Fuse
	PASS	10.5V 0.25A PSU
	PASS	IT Equipment < 3.0mA
	PASS	IT Equipment < 3.0mA
	PASS	5A Fuse
	PASS	5A Fuse
		5A Fuse
GOOD	PASS	13A Fuse
	PASS	
	PASS	3A Fuse
	PASS	3A Fuse
		10A Fuse
GOOD	PASS	13A Fuse

GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	13A Fuse
GOOD	PASS	.25Ω Rpe Limit for 1.5mm CSA 13A
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
	PASS	IT Equipment < 3..5mA
	PASS	13A Fuse
	PASS	IT Equipment < 3..5mA
GOOD	PASS	13A Fuse
	PASS	IT Equipment < 3..5mA
GOOD	PASS	13A Fuse
GOOD	PASS	(0.49Ω Limit) 13a Fuse
GOOD	PASS	RCD Protector
GOOD	PASS	3A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	5A Fuse
GOOD	PASS	5A Fuse
	PASS	12v 1A PSU
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fused
		12V 0.4A PSU 3A Fuse
GOOD	PASS	13A Fuse
	PASS	
	PASS	
	PASS	
	PASS	
GOOD	PASS	5A Fuse
GOOD	PASS	5A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	13A Fuse
	PASS	3A Fuse
GOOD	PASS	5A Fuse
GOOD	PASS	13A Fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
		3A Fuse
	PASS	3A Fuse
	PASS	3A Fuse
	PASS	3A Fuse
	PASS	3A Fuse
	PASS	3A Fuse
	PASS	3A Fuse
	PASS	3A Fuse

	PASS	3A Fuse
	PASS	3A Fuse
		IT Equipment < 3..5mA
		IT Equipment < 3..5mA
GOOD	PASS	13A Fuse
GOOD	PASS	3A Fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
GOOD	PASS	Riso Fail Tested at 500v 13A fuse
	PASS	
		13A Fuse
	PASS	
	PASS	
GOOD	PASS	10A Fuse
GOOD	PASS	10A Fuse
	PASS	
GOOD	PASS	0.702Ω RPE limit
GOOD	PASS	0.702Ω RPE limit
GOOD	PASS	0.702Ω RPE limit
GOOD	PASS	5A Fuse
GOOD	PASS	5A Fuse